

Güntner GCVC RD 050.3/23-51-6104487M Brand new

Specifications

Brand	Güntner
Type	GCVC RD 050.3/23-51-6104487M Brand new
Product type	Air Cooled Condenser
kW	121,9
Number of Fans	6
RPM of the Fans	1240
Refrigerant	Freon
Air Flow in m ³ /h	41.400
diameter fans Ø	500 mm
Surface (m ²)	258,3
Tube volume	25,1
Sizes	3260x850x1920 mm (LxWxH)
Remarks	Y.o.b. 2024
Stock	1



Description

Used Güntner GCVC RD 050.3/23-51-6104487M Brand new

Brand new Güntner GCVC RD 050.3/23-51-6104487M air-cooled condenser on Freon. Complete with 6 Ziehl-Abegg fans - 50/60 Hz - 0,45/0,47 kW - 1240/1260 RPM - diameter 500 mm and a total airflow of 41.400 m³/h. *All components of this used condenser will be tested on adequate functionality, leak-free condition (electro engines), condensing block, and bearings. Choosing HOSBV means buying with warranty. We perform an industrial cleaning. on demand, we can arrange your shipment.



Güntner GmbH & Co. KG Hans-Güntner-Strasse 2 - 5 82256 Fünfenfeldbruck www.guenter.de					
Projektnummer - Project number		101227764			
Gerätebezeichnung - Unit name		GVCV RD 060.3/23-51-6104487M			
Gerät Seriennummer - Unit serial number		504339592/34.00115			
Ventilator/Drehzahl/Stromaufn. - Fan/ID/Speed/Current		VT01524 / 3616 / 1240 min ⁻¹ / 3.2 A			
Umgebungstemperatur - Ambient air temperature		-30 °C / +50 °C			
Herstellungsjahr - Year of manufacture		2024			
Druckgerät Seriennr. - Pressure equipment serial no.		504339592/34.00115			
Volumen - Volume (V)		25.1 l			
Max. zulässiger Druck (PS) Max. permissible pressure (PS)		32 / 0 bar		0 / -1 bar	
Zulässige min./max. Temperatur (TS) Permissible min./max. temperature (TS)		-50 °C / +100 °C		-50 °C / +40 °C	
Prüfdruck(PT)/Prüfmedium - Test pressure(PT)/Test medium		45.8 bar / Druckluft			
Prüfdatum - Test date		2024-08-22			
Fluidegruppe / Zustand - Group of fluid / State		2 / gasförmig - gaseous			





