

Selection Procedure

The following selection procedure is applicable to both reciprocating and screw compressors. (Refer to factory for selection on centrifugal compressors.) The total heat of rejection for the system is determined by adding the evaporator load, expressed in kW, and the absorbed kW of the compressor motor. This procedure applies to both open type and hermetic compressors.

Once the heat of rejection has been determined, multiply it by the factor for the specified operating conditions (condensing temperature and wet bulb temperature) obtained from either Table 1 or Table 2. The resultant figure is then used to select a unit from Table 3.

EXAMPLE

Given: 1000 kW Evaporator Load, Ammonia

Refrigerant at 36°C Condensing

Temperature, 24°C Wet Bulb Temperature

with a 300 kW Compressor.

Selection: Evaporator Load = 1000 kW

Compressor Load = 300 kW Total = 1300 kW

Heat of Rejection

From Table 2, the Capacity Factor for 36°C Condensing Temperature and 24°C Wet Bulb temperature = 1.20

1300 1,20 1560 (Total Heat x (Capacity = (Corrected Heat of Rejection) Factor) Rejection Load) Therefore, from Table 3 select LSCB-370, or LRC-379, or PMCB 375, or PMCB 385 depending upon layout, fan kW, and any other design considerations.

Note:

For screw compressor selections employing water cooled oil cooling, select a condenser for the total kW as in the example. The condenser can then function in one of two ways:

- (1) Recirculating water from the water sump can be used directly in the oil cooler. A separate pump should be employed and the return water should be directed into the water sump at the opposite end from the pump suction.
- (2) The condenser coil can be circuited so that water or a glycol-water mixture for the oil cooler can be cooled in a separate section of the coil. Specify load and water flow required.

For refrigerant injection cooled screw compressors select the condenser in the same manner as shown in the example.

If the oil cooler is supplied by water from a separate source, then the oil cooling load should be deducted from the heat of rejection before making the selection.

TABLE 1 R-22 and R-134a Heat Rejection Factors

Pres	ensing sure, Pa)	Cond. Temp.		WET BULB TEMPERATURE, °C.																
22	134-a	°C	10	12	14	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30
1090	669	30	1,07	1,15	1,25	1,38	1,47	1,57	1,69	1,83	2,00	2,23	2,50	2,86	3,36	_	_	_	_	_
1154	718	32	0,94	1,01	1,09	1,19	1,26	1,32	1,40	1,49	1,60	1,74	1,90	2,11	2,36	_	—	—	—	_
1220	759	34	0,85	0,90	0,97	1,04	1,09	1,14	1,20	1,26	1,34	1,43	1,54	1,66	1,81	2,02	2,31	_	_	_
1253	785	35	0,80	0,85	0,91	0,97	1,02	1,06	1,11	1,15	1,21	1,29	1,37	1,46	1,56	1,71	1,89	2,13	2,41	2,77
1287	814	36	0,77	0,81	0,86	0,92	0,96	1,00	1,04	1,07	1,13	1,19	1,26	1,34	1,43	1,56	1,71	1,90	2,14	2,43
1359	856	38	0,70	0,74	0,78	0,82	0,85	0,88	0,90	0,93	0,96	1,01	1,06	1,11	1,18	1,26	1,35	1,47	1,62	1,78
1431	915	40	0,65	0,67	0,70	0,73	0,76	0,78	0,80	0,83	0,86	0,89	0,93	0,97	1,02	1,08	1,14	1,22	1,32	1,44
1508	978	42	0,59	0,62	0,64	0,67	0,68	0,70	0,72	0,74	0,77	0,80	0,83	0,86	0,89	0,94	0,98	1,04	1,11	1,19
1587	1026	44	0,54	0,56	0,59	0,61	0,62	0,63	0,65	0,66	0,68	0,70	0,73	0,75	0,78	0,82	0,85	0,89	0,92	0,97

TABLE 2 Ammonia (R-717) Heat Rejection Factors

Condensing	Cond.		WET BULB TEMPERATURE, °C.																
Pressure, (KPa)	Temp. °C	10	12	14	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30
1063	30	0,95	1,03	1,12	1,23	1,31	1,40	1,51	1,63	1,79	1,99	2,24	2,56	3,00	_	_	_	_	_
1133	32	0,84	0,90	0,97	1,06	1,12	1,18	1,25	1,32	1,43	1,55	1,70	1,88	2,11	_	_	—	—	—
1206	34	0,76	0,81	0,86	0,93	0,98	1,02	1,07	1,12	1,19	1,28	1,38	1,48	1,61	1,80	2,06	—	—	_
1245	35	0,71	0,76	0,81	0,87	0,91	0,95	0,99	1,03	1,08	1,15	1,23	1,30	1,39	1,53	1,69	1,90	2,15	2,47
1284	36	0,69	0,73	0,77	0,82	0,86	0,89	0,92	0,96	1,01	1,07	1,13	1,20	1,28	1,39	1,53	1,70	1,91	2,17
1365	38	0,63	0,66	0,69	0,73	0,76	0,78	0,81	0,83	0,86	0,90	0,94	0,99	1,05	1,12	1,21	1,31	1,44	1,59
1451	40	0,58	0,60	0,62	0,65	0,67	0,70	0,72	0,74	0,76	0,80	0,83	0,87	0,91	0,96	1,02	1,09	1,18	1,29
1539	42	0,53	0,55	0,57	0,60	0,61	0,63	0,64	0,66	0,68	0,71	0,74	0,76	0,80	0,84	0,88	0,93	0,99	1,06
1630	44	0,49	0,50	0,52	0,54	0,56	0,56	0,58	0,59	0,61	0,63	0,65	0,67	0,70	0,73	0,76	0,79	0,83	0,86

TABLE 3 Unit Heat Rejection Capacity

Model No. kW Base Model No. kW Base Model No. kW Base Model No. kW Base LSCB-36 155 LSCB-210 904 LSCB-400 1722 LSCB-620 2669 41 177 225 969 410 1766 625 2691 48 207 240 1033 430 1851 650 2798 54 232 250 1076 431 1855 660 2841 65 280 280 1205 450 1937 690 2970 70 301 281 1206 460 1980 691 2972 75 323 295 1270 475 2045 720 3100	Model No. LSCB-950 960 980 1000 1020	4090 4133 4219 4305
41 177 225 969 410 1766 625 2691 48 207 240 1033 430 1851 650 2798 54 232 250 1076 431 1855 660 2841 65 280 280 1205 450 1937 690 2970 70 301 281 1206 460 1980 691 2972 75 323 295 1270 475 2045 720 3100	960 980 1000	4133 4219 4305
80 344 300 1292 480 2066 721 3102 90 387 310 1335 490 2109 755 3250 100 431 315 1356 500 2153 770 3315 110 474 330 1421 510 2196 800 3444 120 517 335 1442 515 2217 805 3466 135 581 345 1485 530 2282 820 3532 150 646 355 1528 540 2325 860 3702 155 667 360 1550 550 2368 861 3704 170 732 370 1593 560 2411 900 3875 185 796 385 1657 590 2540 920 3961	1030 1060 1080 1100 1120 1180 1250 1310 1380 1440 1510	4391 4434 4563 4649 4736 4822 5080 5381 5640 5941 6199 6501 6931

	LRC - Centrifugal Fan Models												
Model No.	kW Base	Model No.	kW Base	Model No.	kW Base	Model No.	kW Base	Model No.	kW Base				
LRC - 25 27 29 35 38 42 48 51 58	108 116 125 151 164 181 207 220 250	LRC - 65 72 76 84 91 101 114 108 116	280 310 327 362 392 435 491 465 500	LRC - 128 131 140 155 174 183 190 201 213	551 564 603 667 749 788 818 865	LRC - 225 233 246 188 211 227 240 255 269	969 1003 1059 809 908 977 1033 1098 1158	LRC - 249 287 300 321 336 361 379	1072 1236 1292 1382 1446 1554 1632				

	Power-Mizer Models												
Model No.	kW Base	Model No.	kW Base	Model No.	kW Base	Model No.	kW Base	Model No.	kW Base				
PMCB-190 210 220 235 240 250 275 295 325 350	818 904 947 1012 1033 1076 1184 1270 1399 1507	PMCB-360 375 390 415 435 455 480 510 535 560	1550 1614 1679 1787 1873 1959 2066 2196 2303 2411	PMCB-580 600 630 660 690 725 755 775 815 855	2497 2583 2712 2841 2970 3121 3250 3336 3509 3681	PMCB-885 960 1000 1015 1030 1080 1120 1175 1260 1320	3810 4133 4305 4370 4434 4649 4822 5058 5424 5683	PMCB-1380 1410 1485 1540 1630 1710 1770	5941 6070 6393 6630 7017 7362 7620				

	Alternate Power-Mizer Models*												
Model No.	kW Base	Model No.	kW Base	Model No.	kW Base	Model No.	kW Base	Model No.	kW Base				
PMCB-175 290 330 335 385	753 1248 1421 1442 1657	PMCB-425 450 475 495 540	1830 1937 2045 2131 2325	PMCB-585 645 705 770	2518 2777 3035 3315	PMCB-805 850 910 950	3466 3659 3918 4090	PMCB-1060 1110 1510 1550	4563 4779 6501 6673				

Unit Selections

Selections for all evaporative condensers can be made by using EVAPCO's IES computer selection software.

IES provides quick and accurate selections at the click of a button. In addition to selections, the program displays unit drawings, dimensional and shipping information. Please contact your local sales representative or visit the EVAPCO Europe web.

NOTE: For applications requiring layout or fan kW combinations not shown above, please consult the factory or your EVAPCO representative.

* Alternate Power-Mizer models represent selections for alternate plan area or low fan kW applications. Standard models should be used for the lowest first-cost selection.



Engineering Dimensions & Data Low Silhouette Evaporative Condenser Centrifugal Fan Models LRC 188 to 379




TABLE 5 Engineering Data

		FANS		WEIGH	TS (kg)	R-717	SPRAY	/ PUMP	REMOT	E SUMP	DIN	MENSIONS (r	nm)
UNIT NO.	N°	kW*	m³/s	Shipping	Operating	Operating Charge (kg)	kW	I/s	Liters Req'd***	Conn. Size	HEIGHT H	LENGTH L	WIDHT W
LRC-188	2	15	19,7	3680	5780	94	1,5	25,6	946	200	2121	4629	2388
211	2	11	17,6	4225	6370	119	1,5	25,6	946	200	2311	4629	2388
227	2	15	19,3	4230	6380	119	1,5	25,6	946	200	2311	4629	2388
240	2	18,5	20,8	4235	6380	119	1,5	25,6	946	200	2311	4629	2388
255	2	15	19,0	4920	7165	178	1,5	25,6	946	200	2502	4629	2388
269	2	18,5	20,4	4925	7170	178	1,5	25,6	946	200	2502	4629	2388
LRC-249	2	22	26,3	4410	7265	128	2,2	34,4	1363	250	2121	5553	2388
287	2	18,5	24,3	5110	8035	166	2,2	34,4	1363	250	2311	5553	2388
300	2	22	25,9	5125	8040	166	2,2	34,4	1363	250	2311	5553	2388
321	2	18,5	23,8	5865	8845	204	2,2	34,4	1363	250	2502	5553	2388
336	2	22	25,3	5875	8855	204	2,2	34,4	1363	250	2502	5553	2388
361	2	30	27,9	6010	8985	204	2,2	34,4	1363	250	2502	5553	2388
379	2	30	27,3	6715	9750	242	2,2	34,4	1363	250	2692	5553	2388

For dry operation or for external static pressure up to 125 Pa use next larger size fan motor.
 Refrigerant charge is shown for R-717. Multiply by 1.93 for R-22 and 1.98 for R-134a.

^{***}Liters shown is water in suspension in unit and piping. Allow for additional water in bottom of remote sump to cover pump suction and strainer during operation. (300 mm would normally be sufficient.)



Applications

Bleed-off

Each unit supplied with a pump mounted on the side is furnished with a clear bleed line for visual inspection and a valve which, when fully open, will bleed-off the proper amount of water. If the make-up water supplying to the unit is relatively free of impurities, it may be possible to cut back the bleed, but the unit must be checked frequently to make sure scale is not forming. Make-up water pressure should be maintained between 140 and 340 kPa.

Water Treatment

In some cases the make-up will be so high in mineral content that a normal bleed-off will not prevent scaling. In these cases water treatment will be required and a reputable water treatment company familiar with the local water conditions should be consulted.

Any chemical water treatment used must be compatible with the galvanized construction of the unit. If acid is used for treatment, it should be accurately metered and the concentration properly controlled. The pH of the water should be maintained between 6.5 and 8.0. Units constructed of galvanized steel operating with circulating water having a pH of 8.3 or higher will require periodic passivation of the galvanized steel to prevent the formation of "white rust". Batch chemical feeding is not recommended because it does not afford the proper degree of control. If acid cleaning is required extreme caution must be exercised and only inhibited acids recommended for use with galvanized construction should be used. For more information see EVAPCO Bulletin entitled "Maintenance Instructions".

Control of Biological Contamination

Water quality should be checked regularly for biological contamination, If biological contamination is detected, a more aggressive water treatment and mechanical cleaning program should be undertaken. The water treatment program should be performed in conjunction with a qualified water treatment company. It is important that all internal surfaces be kept clean of accumulated dirt and sludge. In addition, the drift eliminators should be maintained in good operating condition Note: The location of the evaporative condenser must be considered during the equipment layout stages of a project. It is important to prevent the discharge air (potential of biological contamination) from being introduced into the fresh air intakes of the building.

Recirculating Water System - Freeze Protection

Water lines to and from the unit, spray pump and related piping should be heat traced and insulated up to the overflow level in order to protect from freezing.

The unit should not be operated dry (fans on, pump off) unless the basin is completely drained and the unit has been designed for dry operation.

REMOTE SUMP

Whenever a condenser is idled during subfreezing weather, the water in the sump must be protected from freezing and damaging the pan. The simplest and most reliable method of accomplishing this is with a remote sump tank located in a heated space in the building under the condenser. The recirculating water pump is mounted at the remote sump and whenever it is shut-off, all of the water drains into the indoor tank. When a condenser is ordered for remote sump operation, the standard float valve and strainer are omitted, and the unit is provided with an oversized bottom water outlet connection. Where a remote sump is not possible, a supplementary means of heating the pan water must be provided.

FLECTRIC HEATERS

Electric immersion heaters are available factory installed in the basin of the condenser. They are sized to maintain a +4 or +5°C pan water temperature with -18°C ambient air temperature with the fans and pumps off. They are furnished with a thermostat and low water protection device to cycle the heater on when required and to prevent the heater elements from energizing unless they are completely submerged. Components are enclosed in rugged, weatherproof enclosures for outdoor use. The heater power contactors and electric wiring are not included as standard.

Electric Pan Heaters

Model No.	kW*
LSCB 36 to 80 LSCB 90 to 170 LSCB 185 to 250 LSCB 280 to 385 LSCB 281 to 386 LSCB 410 to 560 LSCB 591 to 770 LSCB 820 to 1120 LSCB 400 to 515	2 3 4 (2) 3 5 (2) 4 (2) 5 (2) 8
LSCB 550 to 805 LSCB 800 to 1030 LSCB 1100 to 1610 LRC 25 to 72 LRC 76 to 114 LRC 108 to 183 LRC 190 to 246 LRC 188 to 269	(2) 5 (2) 8 (2) 10 2 3 4 6 7
LRC 249 to 379 PMCB 175 to 240 PMCB 250 to 375 PMCB 290 to 480 PMCB 450 to 775 PMCB 850 to 1030 PMCB 1060 to 1550 PMCB 435 to 580 PMCB 435 to 580 PMCB 600 to 885 PMCB 1015 to 1120 PMCB 1110 to 1770	9 5 (2) 4 8 (2) 6 (2) 8 (4) 6 (2) 6 (2) 8 (2) 12 (2) 16

^{*} Electric heater selection based on -18°C ambient temperature. For alternate low ambient heater selections, consult the factory.



Steel Support


The recommended support for EVAPCO condensers is structural "I" beams located under the outer flanges and running the entire length of the unit. Mounting holes, 19mm in diameter are located in the bottom channels of the pan section to provide for bolting to the structural steel. (Refer to certified drawings from the factory for bolt hole locations.)

Beams should be level to within 3mm per 2m before setting the unit in place. Do not level the unit by shimming between it and the "I" beams as this will not provide proper longitudinal support.





End Elevations



LRC DIMENSIONS										
	Mod	els		Α	В					
LRC	25	to	72	3083	1029					
LRC	76 108	to to	114 183	3731 4636	1540 1540					
LRC	190 188 249	to to to	246 269 379	5553 4629 5553	1540 2388 2388					

LSCB DIMENSIONS											
	Mod	els		Α	В						
LSCB	36	to	80	1826	1235						
	90	to	120	2724	1235						
	135	to	170	3651	1235						
LSCB	185	to	250	3645	1664						
	280	to	385	5490	1664						
LSCB	281	to	386	3651	2388						
	410	to	560	5486	2388						
	581	to	770	7341	2388						
	820	to	1120	11011	2388						
LSCB	400	to	515	3648	2991						
	550	to	805	5493	2991						
	800	to	1030	7334	2991						
	1100	to	1610	11024	2991						

	PMCB DIMENSIONS											
	Mod	els		Α	В							
PMCB	175 250	to to	240 375	3648 5493	1927 1927							
PMCB	290 450 850 1060	to to to	480 775 1030 1550	3648 5490 7334 11024	2991 2991 2991 2991							
PMCB	435 600 1015 1110	to to to to	580 885 1120 1120	3651 5490 7341 11024	3620 3620 3620 3620							