

## Your partner for used commercial and industrial refrigeration equipment

### **DWM DLSGE-401-EWL**

### **Specifications**

Marca	DWM
Тіро	DLSGE-401-EWL
Refrigerante	Freon
kW at -20ºC/+40ºC	7.71
kW at -30ºC/+40ºC	4.51
kW at -40ºC/+40ºC	2.07
kW at -45ºC/+40ºC	1.20
m3 / h	22.5
Comentarios	Our capacity table is
	based on Manufacturer
	spec. We would like to
	know which refrigerant is
	in your system
Comentarios	check working conditions
	in attached pdf file
Peso kg.	88
Stock	1



#### Description

#### Used DWM DLSGE-401-EWL

Used semi-hermetic compressor DWM -Copeland DLSGE-401-EWL. Our capacity table is based on the used type of Freon. You can also use this compressor(s) on alternative types of Freon. For all the other specs (if available), see the picture of the manufacturer model plate or the attached pdf file. \*Why choose for HOSBV? Were not only the largest used refrigeration specialist in Europe, but also, we deliver all equipment including an extensive test, warranty and industrial cleaning. \*Optional we can also perform a new paint job and arrange the logistics.

www.hosbv.com



# Your partner for used commercial and industrial refrigeration equipment





#### Cooling capacity [kW]

t <sub>c</sub> \ t <sub>e</sub>	-50	-45	-40	-35	-30	-25	-20
25	1.14	1.94	3.02	4.36	5.92	7.67	9.59
30	0.94	1.68	2.69	3.96	5.44	7.12	8.96
35	0.77	1.43	2.37	3.56	4.97	6.57	8.33
40	0.61	1.20	2.07	3.18	4.51	6.03	7.71
45	5	1.7	1.78	2.81	4.06	5.50	7.09
50	-	-	-	2.46	3.63	4.98	6.48
55	-	1.00		2.12	3.20	4.47	5.88
ver input	and the second						
ver input t <sub>c</sub> ∖t <sub>e</sub>	<u>[kW]</u> -50	-45	-40	-35	-30	-25	-20
	and the second	-45 1.87	-40 2.22	-35 2.58	-30 2.91	-25 3.21	
t <sub>c</sub> \ t <sub>e</sub>	-50						3.44
t <sub>c</sub> \ t <sub>e</sub> 25	- <b>50</b> 1.55	1.87	2.22	2.58	2.91	3.21	3.44 3.65
t <sub>c</sub> \ t <sub>e</sub> 25 30	-50 1.55 1.53	1.87 1.87	2.22 2.25	2.58 2.64	2.91 3.02	3.21 3.36	-20 3.44 3.65 3.84 4.01
t <sub>c</sub> \ t <sub>e</sub> 25 30 35	-50 1.55 1.53 1.49	1.87 1.87 1.86	2.22 2.25 2.27	2.58 2.64 2.69	2.91 3.02 3.11	3.21 3.36 3.50	3.44 3.65 3.84
t <sub>c</sub> \ t <sub>e</sub> 25 30 35 40	-50 1.55 1.53 1.49 1.44	1.87 1.87 1.86 1.83	2.22 2.25 2.27 2.27	2.58 2.64 2.69 2.73	2.91 3.02 3.11 3.19	3.21 3.36 3.50 3.62	3.44 3.65 3.84 4.01