

Güntner GCHV RD 080.1NF/25A-42

Specifications

Merk	Güntner
Type	GCHV RD 080.1NF/25A-42
Product type	Drycooler
Capaciteit kW	868,2*
Aantal Ventilatoren	10
Toerental Ventilatoren	660/515
Koudemiddel	Glycol
Luchtstroom in m ³ /h	146.200
diameter ventilatoren Ø	800 mm
Oppervlakte (m ²)	1651 m ²
Inhoud leidingen	123,3 dm ³
Afmetingen	9400x2240x1500 mm (LxWxH)
Opmerkingen	Y.o.b. 2017
Remarks	*Capacity is based on a medium inlet temperature of 60°C and an outlet temperature of 40°C
Stock	1



Description

Used Güntner GCHV RD 080.1NF/25A-42

Gebruikte Güntner GCHV RD 080.1NF/25A-42 luchtgekoelde drycooler bouwjaar 2017. Compleet met 10 EBM-papst ventilatoren - 50 Hz - 0,98/0,57 kW - 660/515 RPM - diameter 800 mm en totaal luchtstroom van 146.200 m³/u.



ERC Oltner GmbH & Co KG Hans Oltner Strasse 2-6 62584 Frankenthal/Deutsch www.guntner.de			
Projektnummer - Project number		101045649	
Gerätebezeichnung - Unit name		GCH IV RD 080 1NF/25A-42	
Ul Nummer - Ul number		141 0LEV 292 074.009K M	
Gerät Seriennummer - Unit serial number		40451162908 01218	
Ventilator/AD/Drehzahl/Stromaufnahme - Fan/Speed/Current		V1031540 / 2620 / 515 min -1 / 1.21 A	
Umgebungstemperatur - Ambient air temperature		30 °C / +50 °C	
Herstellungsjahr - Year of manufacture		2017	
Druckgerät Seriennr. - Pressure equipment serial no.		40451162908 01219	
Volumen - Volume (M)		123.3 l	
Max. zulässiger Druck (PS)		32 / 0 bar	
Max. permissible pressure (PS)		0 / -1 bar	
Zulassung min./max. Temperatur (TS)		-50 °C / +100 °C	
Permissible min./max. temperature (TS)		-5 °C / +40 °C	
Prüfdruck(P)/Prüfmedium - Test pressure(P)/Test medium		35.2 bar / Druckluft - Compressed air	
Prüfdatum - Test date		2017.03.17	
Fluidgruppe / Zustand - Group of fluid / State		2 / gasformig - gaseous	





